

**pbscommissions - Case#: MHRB\_2020-0001**

---

**From:** Robert and/or Christina Aranguren <villageduo@gmail.com>  
**To:** pbscommissions <pbscommissions@mendocinocounty.org>  
**Date:** 7/20/2020 11:57 AM  
**Subject:** Case#: MHRB\_2020-0001

---

Mendocino Historic Review Board  
Dept. of Planning and Building Services  
County of Mendocino  
120 West Fire Street  
Fort Bragg, CA. 95437

**RECEIVED**  
JUL 20 2020

**Planning & Building Services**

Re: Case#: MHRB\_2020-0001

July 20, 2020

Chair Lamb, Board Members Kappler and Roth;

Please refer to the following 2019 California Solar Permitting Guidebook requirement, item 4.1.2:

**4. FireSafetyProvisions**

4.1.2 Solar PV systems installed on grade: Solar PV panels that are part of a stand-alone, ground-mounted solar PV panel structures, with no use and no potential use underneath are generally considered equipment and therefore the fire/roof classification requirements would not apply. *The solar PV panels will require a clear, brush free area of 10 feet around the installation.* (Based on the definition of a roof assembly in CBC Section 202.)

Thank you,

Bob Aranguren  
Mendocino