

# Mendocino Coast Water Works

Post Office Box 144  
Mendocino, CA 95460  
707 937-0478  
Contractor License No. 887988

## Water System Report

**Client/Name:** Peter White at Best Realty

**Location:** 1656 Cameron Road, Elk, CA

**Well Casing/Construction:** 8" steel casing/ drilled well

**Total Depth:** 55' from surface

**Static Level:** 15' from surface

**Recovery Rate:** .85 gpm after 4 hour draw down

**Bacteria Lab Report:** Delivered to Alpha Labs, results to be forwarded

**Coliform:**

**E. Coli:**

### Notes:

Steel casing should be relined with PVC.

### Recommendations:

Disinfect well and seal properly.

**Tested by:** TJ Britton

**Date:** 9-11-2019

<1.1



# Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Bay Area Laboratory  
 6398 Dougherty Rd #35, Dublin CA 94568  
 925-828-6226 F) 925-828-6309

Central Valley Laboratory  
 9080 Union Park Way #113, Elk Grove CA 95624  
 916-686-5190 F) 916-686-5192

Corporate Laboratory  
 208 Mason Street, Ukiah CA 95482  
 707-468-0401 F) 707-468-5267  
 email: clientservices@alpha-labs.com

ELAP Certifications  
 Ukiah 1551 / Dublin 2728 / Elk Grove 2922  
 816-686-5190 / 916-686-5192

Report to		Invoice to (if different)		Project Information		Analysis Request		TAT		Temp upon Receipt °C			
Company: MC Waterworks Inc Address: P.O. Box 144 Mendocino, CA 95460 Phone/Fax: (707)937-0478 Email Address: mcwater@mcn.org		Contact: Eli Rolfe Email Address: Address: Phone/Fax:		Project ID: 1656 Cemen Project No: PO Number:		Standard: 10 days <input checked="" type="checkbox"/> RUSH: 5 days <input checked="" type="checkbox"/> 48 hours <input type="checkbox"/> Other: _____ days <input type="checkbox"/>		Lab preapproval required Ukiah temp: 20 Dublin temp: Elk Grove temp:		Sample Notes or DDW Source Numbers: Rec w/ coupon 10 DAY TAT Per Eli (90)		Signature below authorizes work under terms stated on reverse side.	
Sample Identification		Container		Preservative		Matrix		Total Number of Containers per Sample ID		DDW Write On EDT Transmission?			
1656 Cemen RY Sample Date/Time 10-17-19 @ 1700 Per Eli		40ml Vial Poly Glass Sleeve Other		H2SO4 HNO3 HCl Other		Water Soil Other		1 X TC R column 10 tube		Yes <input type="checkbox"/> No <input type="checkbox"/>			
Relinquished by		Received by		Date		Time		State System Number:		CA Geotracker EDF Report?			
Via Mendo Stage		[Signature]		10/18/19		1440		10-18-19		Yes <input type="checkbox"/> No <input type="checkbox"/>			
Global ID: EDF to (Email Address): Travel and Site Time:		Sampling Company Log Code: Mileage: Misc. Supplies:		If "Y" please enter the Source Number(s) in the column above		DDW Write On EDT Transmission?		Yes <input type="checkbox"/> No <input type="checkbox"/>		CA Geotracker EDF Report?			





Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Mendocino Coast Waterworks  
P.O. Box 144  
Mendocino, CA 95460

Project Manager: Eli Rolfe  
Project: Coliform  
Project Number: 1656 Cameron Rd

Reported:  
11/01/19 15:16

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
<b>1656 Cameron Rd (19J2399-01)</b>									
<b>Microbiological Parameters by APHA Standard Methods</b>									
Total Coliforms	ND MPN/100mL	1.1	1	AJ94367	10/18/19 16:30	10/22/19 14:45	1551	SM9221B	
Fecal Coliforms	ND MPN/100mL	1.1	1	AJ94367	10/18/19 16:30	10/22/19 14:45	1551	SM9221B,E	

Sampled: 10/17/19 17:00

Sample Type: Water